



**CERTIFICATE OF CONSTANCY OF PERFORMANCE**  
**2268-CPR-346**

Notified body No. 2268

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

**External fire resisting and smoke control pedestrian doorset**  
(product)

**Single leaf steel hinged doorset LSC T**

(see annex 1)  
(product type and parameters)

produced by the manufacturer

**UAB "Asmodas"**

Dubysos str. 23, LT 91181, Klaipėda, Lithuania/ company code: 241856270  
(name and address of the manufacturer, company code)

in the manufacturing plant  
Skaidrioji str. 22-1, LT 96155, Gargždai, Lithuania  
(address of the manufacturing plant)

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard

**EN 16034:2014** \* (shall only be applied together with EN 14351-1:2006+A2:2016\*)

under system 1 are applied and that the products and the factory production control fulfils all the prescribed requirements set out above.

This certificate was first issued on **2021-04-02** and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product and the factory production control itself are not modified significantly.

The certificate issued on 2021-04-02.

Romas Skripka  
Certification business unit manager

\* - this standard is adopted as Lithuanian national standard.

UAB „Kiwa Inspecta“  
Ukmergės g. 308,  
LT-12110 Vilnius, Lietuva  
Tel. +370 5 2031395  
Fax.+ 370 5 2031396  
lithuania@kiwa.com  
[www.kiwa.lt](http://www.kiwa.lt)



# CERTIFICATE OF CONSTANCY OF PERFORMANCE

2268-CPR-346

Annex 1



<b>Product:</b> single leaf external steel hinged doorset LSC T			
<b>Intended use:</b> fire and/or smoke compartmentation and/or escape routes			
<b>Essential Characteristics</b>	<b>European Standards(s) related to essential characteristics</b>	<b>Performance<sup>1)</sup></b>	<b>Notes</b>
Resistance to fire	LST EN 1634-1 LST EN 13501-2	E 30, EI <sub>2</sub> 30, EI <sub>1</sub> 30, EW 30	class
Smoke control	LST EN 1634-3 LST EN 13501-2	S <sub>a</sub> S <sub>200</sub>	class
Ability to release	EN 16034, clause 4.3	NPD <sup>2)</sup>	
Self-closing durability	LST EN 1191 LST EN 16034	200 000 C <sub>5</sub>	cycles class
Durability of ability to release	EN 16034, clause 4.5.1	NPD <sup>2)</sup>	
Durability of self-closing – against degradation (cycling testing)	EN 16034, clause 4.5.2.1	NPD <sup>2)</sup>	
Durability of self-closing – against ageing (corrosion)	EN 16034, clause 4.5.2.2	NPD <sup>2)</sup>	
<sup>1)</sup> the scope of products covered by this certificate can be found in the extended application report No. 04-400-18-07_revision_1 (2021-03-31) and classification report No. 04-400-18-05_revision_1 (2021-03-31);			
<sup>2)</sup> NPD – No Performance Determined.			

Romas Skripka  
Certification business unit manager  
2021-04-02