



CERTIFICATE OF CONSTANCY OF PERFORMANCE
2268-CPR-391

Notified body No. 2268

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

External fire resisting and smoke control pedestrian doorset

(product)

Double leaf steel hinged doorset DSA6 MAX

(see annex 1)

(product type and parameters)

produced by the manufacturer

UAB "Asmodas"

Dubysos str. 23, LT 91181, Klaipėda, Lithuania/ company code: 241856270

(name and address of the manufacturer, company code)

in the manufacturing plant

Skaidrioji str. 22-1, LT 96155, Gargždai, Lithuania

(address of the manufacturing plant)

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard

EN 16034:2014 * (shall only be applied together with EN 14351-1:2006+A2:2016*)

under system 1 are applied and that the products and the factory production control fulfils all the prescribed requirements set out above.

This certificate was first issued on **2022-03-18** and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product and the factory production control itself are not modified significantly.

The certificate issued on 2022-03-18.

Mindaugas Grigonis
Certification business unit manager

* - this standard is adopted as Lithuanian national standard.

CERTIFICATE OF CONSTANCY OF PERFORMANCE

2268-CPR-391

Annex 1



Product: double leaf external steel hinged doorset DSA6 MAX			
Intended use: fire and/or smoke compartmentation and/or escape routes			
Essential Characteristics	European Standards(s) related to essential characteristics	Performance¹⁾	Notes
Resistance to fire	LST EN 1634-1 LST EN 13501-2	E 60, EI ₂ 60, EW 60 ¹⁾	class
Smoke control	LST EN 1634-3 LST EN 13501-2	S _a S ₂₀₀	class
Ability to release	EN 16034, clause 4.3	NPD ²⁾	
Self-closing durability	LST EN 1191 LST EN 16034	200 000 C5	cycles class
Durability of ability to release	EN 16034, clause 4.5.1	NPD ²⁾	
Durability of self-closing – against degradation (cycling testing)	EN 16034, clause 4.5.2.1	NPD ²⁾	
Durability of self-closing – against ageing (corrosion)	EN 16034, clause 4.5.2.2	NPD ²⁾	
¹⁾ the scope of products covered by this certificate can be found in the extended application report No. 04-613-20-03 (2022-03-17) and classification report No. 04-613-20-04 (2022-03-17);			
²⁾ NPD – No Performance Determined.			

Mindaugas Grigonis
Certification business unit manager
2022-03-18