



**CERTIFICATE OF CONSTANCY OF
PERFORMANCE
2268-CPR-346**



Notified body No. 2268

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

External fire resisting and smoke control pedestrian doorset
(product)

Single leaf steel hinged doorset "LSC T"
(product type)

produced by the manufacturer

UAB "Asmodas"

Dubysos str. 23, LT 91181, Klaipėda, Lithuania / company code:
241856270

(name and address of the manufacturer, company code)

in the manufacturing plant

Skaidrioji str. 22-1, LT 96155, Gargždai, Lithuania

(address of the manufacturing plant)

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 16034:2014 * (shall only be applied together with EN 14351-1:2006+A2:2016*)

under system 1 are applied and that the products and the factory production control fulfils all the prescribed requirements set out above.

This certificate was first issued on **2021-04-02** and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product and the factory production control itself are not modified significantly.

The certificate issued on **2024-02-07**

Laimutė Ditauskienė 
Certification business unit manager

* - this standard is adopted as Lithuanian national standard.

UAB „Kiwa Inspecta“
Ukmergės g. 308,
LT-12110 Vilnius, Lietuva
Tel. +370 5 2031395
Fax. + 370 5 2031396
lithuania@kiwa.com
www.kiwa.lt



Nr. LA 03 013

Informacija apie šio sertifikato galiojimą skelbiama www.kiwa.lt

CERTIFICATE


CERTIFICATE OF CONSTANCY OF PERFORMANCE
2268-CPR-346
Annex



Performance characteristics:

Product: fire resistant and smoke control single leaf external steel hinged doorset „LSC T“			
Essential Characteristics	European Standards related to essential characteristics	Performance	Notes
Resistance to fire	LST EN 1634-1 LST EN 13501-2	E 30, EI ₁ 30, EI ₂ 30, EW 30 ¹⁾	class
Smoke control	LST EN 1634-3 LST EN 13501-2	S _a ¹⁾ S ₂₀₀ ¹⁾	class
Self-closing durability	LST EN 1191 LST EN 16034	200 000 ¹⁾ C ₅ ¹⁾	cycles class

¹⁾ the scope of products covered by this certificate can be found in the extended application report No. 04-400-18-07_revision_1 (2021-03-31) and classification report No. Nr. 04-400-18-05_revision_1 (2021-03-31).

Laimutė Ditauskienė 
Certification business unit manager
2024-02-07